

Permit No. \_\_\_\_\_

Owner: \_\_\_\_\_

Site Address: \_\_\_\_\_

Contractor: \_\_\_\_\_



# RESIDENTIAL CERTIFICATE OF LIGHTING FIXTURES

## SECTION N1107 LIGHTING

**N1107.1 General.** The provisions of this section apply to lighting equipment, related controls and electric circuits serving all conditioned and unconditioned interior floor space and exterior building facades of all dwelling units and guest rooms within residential buildings and structures, or portions thereof.

**N1107.2 High-efficiency interior lighting.** All permanently installed lighting fixtures shall be high efficiency light sources. The building official shall be notified in writing at the final inspection that the permanently installed lighting fixtures have met this requirement.

**Exception:** Two permanently installed lighting fixtures are not required to be high-efficiency light sources when controlled by a dimmer or automatic control.

**N1107.3 High-efficiency exterior lighting.** All exterior lighting fixtures affixed to the exterior of the building shall be high-efficiency light sources.

**Exception:** Two permanently installed lighting fixtures are not required to be high-efficiency light sources when controlled by automatic control.

**N1107.4 Solar interconnection pathway.** A square metal junction box not less than 4 inches by 4 inches (102 mm by 102 mm) with a metal box cover shall be provided within 24 inches (610 mm) horizontally or vertically of the main electrical panel. A minimum 3/4-inch (19 mm) non-flexible metal raceway shall extend from the junction box to a capped roof termination or to an accessible location in the attic with a vertical clearance of not less than 36 inches (914 mm). Where the raceway terminates in the attic, the termination shall be located not less than 6 inches (152 mm) above the insulation. The end of the raceway shall be marked as "RESERVED FOR SOLAR."

**Exception:** In lieu of 3/4-inch (19 mm) nonflexible metal raceway, a minimum No. 10 copper 3-wire MC cable installed from the junction box to the termination point including 6 inches (152 mm) additional wire is permitted.

I acknowledge by my signature below, that I have met the requirements as specified in Section N1107, and of its exceptions as applicable, of the 2021 Oregon Residential Specialty Code (ORSC).

Printed Name: \_\_\_\_\_ Date: \_\_\_\_\_

General Contractor/Owner Signature: \_\_\_\_\_